

# REPORT DOCUMENTATION PAGE

Form Approved  
OMB No. 0704-0188

Public reporting burden for this collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden, to Washington Headquarters Services, Directorate for Information Operations and Reports, 1215 Jefferson Davis Highway, Suite 1204, Arlington, VA 22202-4302, and to the Office of Management and Budget, Paperwork Reduction Project (0704-0188), Washington, DC 20503.

1. AGENCY USE ONLY (Leave blank)	2. REPORT DATE	3. REPORT TYPE AND DATES COVERED
		FINAL REPORT 30 Sep 93 - 31 Mar 96
4. TITLE AND SUBTITLE		5. FUNDING NUMBERS
development of compact 1.06 and 2.1 MICRON LASERS		62228D 4276/AS
6. AUTHOR(S)		
Professor Kushawaha		
7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES)		
Howard University Washington, DC 20059		
AFOSR-TR-96 0558		

9. SPONSORING/MONITORING AGENCY NAME(S) AND ADDRESS(ES)	10. SPONSORING/MONITORING AGENCY REPORT NUMBER
AFOSR/NE 110 Duncan Avenue Suite B115 Bolling AFB DC 20332-8080	F49620-93-1-0571

11. SUPPLEMENTARY NOTES	12a. DISTRIBUTION/AVAILABILITY STATEMENT	12b. DISTRIBUTION CODE
	APPROVED FOR PUBLIC RELEASE: DISTRIBUTION UNLIMITED	

13. ABSTRACT		
During the project period, extensive studies of the laser performance of a Nd: and Ho:Tm ions doped in YAG ( $Y_3Al_5O_12$ ), KGW (KGd (WO <sub>4</sub> ) <sub>2</sub> ) host crystals pumped by diode lasers operating in continuous wave or pulsed modes of operation. The diode lasers were temperature tuned to select the appropriate wavelengths to pump the Nd-ions at 785 nm. The laser action from these ions was observed at 1.06 and 2.1 micron, respectively. These laser actions were observed by using various pumping schemes such as end-pumping or side-pumping in different configurations such as fixed rod, rotating disks, and moving slabs. These configurations were used only in case of Nd:YAG or Nd:KGW laser crystals. For Tm:Ho:LuAG, only the rod configuration was used at low temperature to observe the laser action at 2.1 micron. A slightly improved laser performance as observed using the rotating disk or moving slab configurations as compared to the fixed configurations. The Nd:YAG and Nd:KGW laser experiments were also performed at very low temperature (approx. 78 K). The laser performance from Nd:KGW at the low temperature was found to be slightly better than the Nd:YAG laser. These results have either been published or submitted for publication in refereed journals.		
14. SUBJECT TERMS		

DTIC QUALITY INSPECTED 3		
17. SECURITY CLASSIFICATION OF REPORT	18. SECURITY CLASSIFICATION OF THIS PAGE	19. SECURITY CLASSIFICATION OF ABSTRACT
UNCLASSIFIED	UNCLASSIFIED	UNCLASSIFIED
20. LIMITATION OF ABSTRACT		

1996125186

RECEIVED

96 OCT 24 PM 1:59

# Howard University

Washington DC 20059

ASSOC. V.P. FOR RESEARCH

1. NAME OF THE AGENCY: Air Force Office of Scientific Research
2. PERIOD COVERED BY REPORT (Final): 30 September 1993 - 31 May 1996
3. TITLE OF THE PROPOSAL: Development of compact 1.06 and 2.1 Micron Lasers
4. CONTRACT OR GRANT NO: F49620-93-1-0571
5. NAME OF THE INSTITUTION: Howard University
6. AUTHOR OF THE REPORT: Vikram S. Kushawaha
7. LIST OF THE MANUSCRIPTS SUBMITTED OR PUBLISHED UNDER WRIGHT LABORATORY SPONSORSHIP DURING THIS REPORTING PERIOD:
  1. Relative performance of a 1.06  $\mu$ m laser with various Nd doped crystals  
V. Kushawaha and L. Major, Optics and Laser Techn. 26 351 (1994)
  2. Effect of Nd concentration on the Nd:KGW laser  
V. Kushawaha, A. Michael, and L. Major, Appl. Phys. B58, 533 (1994)
  3. Diode End Pumped High Efficiency Nd:YAG Laser  
V. Kushawaha and Y. Chen, Appl. Phys. B59, 659 (1994)
  4. Q-switched operation of a SGGM laser  
V. Kushawaha and A. Michael, Optics and Laser Techn. 27, 137 (1995)
  5. Rotating Disk Diode Pumped Continuous Wave Nd:YAG Laser  
Y. Chen and V. Kushawaha, Appl. Phys. B61, 525 (1995)
  6. CW and quasi-CW diode laser pumped Nd:SSGM  
V. Kushawaha and Y. Chen, Appl. Phys. B60 67 (1995)
  7. Efficiency of diode pumped 1.35  $\mu$ m laser from diode pumped Nd:KGW  
V. Kushawaha, Y. Yan, and Y. Chen, Appl. Phys. B62, 533 (1996)
  8. High efficiency continuous wave diode pumped Tm:Ho:LuAG laser at 2.1 $\mu$ m  
V. Kushawaha, Y. Chen, Y. Yan and L. Major, Appl. Phys. B62, 109 (1996)
  8. Efficient laser operation of diode pumped Nd:KGd(WO<sub>4</sub>)<sub>2</sub> crystal at 1.067  $\mu$ m  
Y. Chen, L. Major, and V. Kushawaha, Appl. Opt. (In Press 1996)
  9. Diode Pumped Moving Nd:YAG and Nd:KGW Slab Lasers  
Y. Chen, L. Major, Y. Yan, and V. Kushawaha, Appl. Phys. B (Submitted 96)
8. SCIENTIFIC PERSONNEL SUPPORTED BY THIS PROJECT AND DEGREES AWARDED DURING THIS REPORTING PERIOD: None
9. REPORT OF INVESTIGATION (BY TITLE ONLY): None

10. BRIEF OUTLINE OF RESEARCH FINDINGS:

During the project period (October 1, 1993 - May 15, 1996 ), we have extensively studied the laser performance of a Nd: and Ho:Tm ions doped in YAG ( $Y_3 Al_5 O_{12}$ ), KGW (  $KGd (WO_4)_2$  ) and LuAG ( $Lu_3 Al_5 O_{12}$ ) host crystals pumped by diode lasers operating in continuous wave or pulsed modes of operation. The diode lasers were temperature tuned to select the appropriate wavelengths to pump the Nd-ions at 808 nm and Ho-ions at 785 nm. The laser action from these ions was observed at 1.06 and 2.1 micron, respectively. These laser actions were observed by using various pumping schemes such as end-pumping or side-pumping in different configurations such as fixed rod, rotating disks, and moving slabs. These configurations were used only in case of Nd:YAG or Nd:KGW laser crystals. For Tm:Ho:LuAG, only the rod configuration was used at low temperature to observe the laser action at 2.1 micron. A slightly improved laser performance was observed using the rotating disk or moving slab configurations as compared to the fixed configurations. The Nd:YAG and Nd:KGW laser experiments were also performed at very low temperature ( approx. 78 K). The laser performance from Nd:KGW at the low temperature was found to be slightly better than the Nd:YAG laser. These results have either been published or submitted for publication in refereed Journals.